



SWEDISH TYPE APPROVAL 0275

WITH DECISION ON PRODUCTION CONTROL

KEYWORD: Tap water

Holder: SANHA GmbH & Co. KG

Im Teelbruch 80, 45219 Essen, Germany

Tel: +49 2054 925/0

Fax: +49 2054 925 250

E-mail: info@sanha.com

Webb: <http://www.sanha.com>

Product name: NiroSan series 9000, pressfitting system

Stainless steel pipe system and pressfittings in dimensions Ø 15, 18, 22, 28, 35, 42, 54, 64, 76.1, 88.9, 108 mm.

Intended use

Pipe system for use in tap water installations with visible montage

Maximum operating pressure 1,0 Mpa

Approval

Products made and installed according to related documents are approved with respect to the following sections of the Swedish Building Regulations (BBR):

Installations for tap water	6:62
Design – 1 st paragraph	6:625

For the intended use the products meets the following requirements of PBL, regulations governing the technical properties of materials, products etc. used in construction works Chapter 8 Section 4 about the technical characteristics of buildings and constructions.

3. Protection with regard to hygiene, health and environment

Appendix 1: Associated documents	15/08/2016
Appendix 2: Product marking	15/08/2016
Appendix 3: Control	15/08/2016
Appendix 4: Basis for approval	15/08/2016

Kiwa Sverige AB
Campus Gräsvik 1
SE-371 75 Karlskrona


Tel +46 (0)455-30 56 00
Fax +46 (0)455-104 36
bygg@kiwa.se
www.kiwa.se



Date of decision: 15/08/2016


Valid until: 14/08/2021

Kiwa Sverige AB


Magnus Jerlmark
Technical manager

Ref. no: 611/16

Previous ref. no.: 074/12


Deo Yamabo
Project leader