



**Centrum stavebního inženýrství a.s. Praha**  
**Centre of Building Construction Engineering Prague**

Akreditované zkušební laboratoře, Autorizovaná osoba,  
Oznámený subjekt, Certifikační orgán  
Accredited Test Laboratories, Authorised Body,  
Notified Body, Certification Body  
Pražská 16, 102 00 Praha 10



**CERTIFICATE**  
**OF CONSTANCY OF PERFORMANCE**

**1390 – CPR – 0342/12/P**

In compliance with the Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

***Factory made mineral wool products used for building equipment and industrial instalations, sold under the trade mark***

***Alu Lamella Mat; Larock 40 ALS***

***Klimafix; Ventizol***

*(trade marks and type codes according to list given in the annex to the certificate)*

Methods of measurement and product description are listed in the report  
No. 1390-CPR-0342/12/P-2015 from 10. 04. 2015

produced by :

**ROCKWOOL Polska, Sp.z o.o.**  
**ul. Kwiatowa 14**  
**66-131 Cigacice, Poland**

and produced in the :  
manufacturing plant

**ROCKWOOL Polska, Sp.z o.o.**  
**ul. Kwiatowa 14**  
**66-131 Cigacice, Poland (production line CIG 4)**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard

**EN 14 303:2009 + A1:2013**

under system 1 are applied and that the product fulfills all the prescribed requirements set out above.

This certificate was first issued on 08. 08. 2012 as a certificate in accordance with CPD and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performances of the declared characteristics, do not change, and the construction product, and the manufacturing conditions in the plant are not modified significantly, unless suspended or withdrawn by the product certification body.

Notified Body 1390  
Prague, 10. 04. 2015



  
**Ing. Petr Kučera, CSc.**  
Deputy of Notified Body 1390





**Centrum stavebního inženýrství a.s. Praha**  
**Centre of Building Construction Engineering Prague**

Akreditované zkušební laboratoře, Autorizovaná osoba,  
Oznámený subjekt, Certifikační orgán  
Accredited Test Laboratories, Authorised Body,  
Notified Body, Certification Body  
Pražská 16, 102 21 Praha 10



**Annex to the CERTIFICATE OF CONSTANCY OF PERFORMANCE**  
**1390-CPR-0342/12/P**

The certificate covers the following products of Rockwool Polska Sp. z o.o.,  
ul. Kwiatowa 14, 66-131 Cigacice, Poland

tab 1

Trade mark	Thermal conductivity W/m·K	Reaction to fire	Type code in accordance with EN 14 303
Alu Lamella Mat Larock 40 ALS	see tab. 2	A1	MW EN 14303-T4-ST(+)250-WS1-MV2
Klimafix Ventizol		A2-s1;d0	MW EN 14303-T4-ST(+)50-WS1-MV2

tab 2

Trade mark	$\lambda_D$ Thermal dependence of thermal conductivity W/m·K							
	10	50	100	150	200	250	-	-
Alu Lamella Mat Larock 40 ALS	0,038	0,050	0,061	0,076	0,096	0,118	-	-

Trade mark	$\lambda_D$ Thermal dependence of thermal conductivity W/m·K							
	10	20	30	40	50	-	-	-
Klimafix Ventizol	0,038	0,040	0,042	0,044	0,048	-	-	-

Notified Body 1390  
Prague, 10. 04. 2015



  
Ing. Petr Kučera, CSc.  
Deputy of Notified Body 1390