




Flexible walls
Kipsilevyseinät
Byggnadsdel av gips



Rigid walls and floors
Kivirakenteiset seinät ja välipohjat
Massiv byggnadsdel, tak och bjälklag



- (1) Fire damper valve/Palopeltiventtiili/Brandventil
- (2) Mounting ring/Kiinnityskehys/Fästram KKT
- (3) Steel duct/Teräskanava/Kanal av stål

Penetration seal/Läpiviennin tiivistys/Tätning av genomföring:

- (4) 5-10 mm Fire-resistant mass/Palomassa/Brandmass Silacoll 100 or similar/tai vastaava/eller motsvarande
- (5) Min 25 mm Mortar/Betonilaasti/Murbruk

Mounting frame KKT is fixed to the air duct and wall or floor structure with galvanized rivets or screws. Fire damper valve KSOF is attached to mounting frame KKT with screwing motion.


Kiinnityskehys KKT kiinnitetään kanavaan ja seinä- tai katto-rakenteeseen teräksisillä pop-niiteillä tai ruuveilla ja venttiili kierretään kiinni kiinnityskehkyseen.

Fästramen KKT ansluts i kanalen och i byggnadsdel, tak eller bjälklag, med popnit av stål eller plåtskruvar. Ventilen vrider mot fästramen på sin plats.



$$q = k \sqrt{\Delta p_m} \quad (\text{l/s}) \quad (\text{Pa})$$

$$q = 3.6k \sqrt{\Delta p_m} \quad (\text{m}^3/\text{h}) \quad (\text{Pa})$$



KSOF-100	k
-15	0,5
-12	0,8
-10	1,0
-5	1,4
0	1,9
+5	2,3
+10	2,8

KSOF-125	k
-10	1,5
-5	2,1
0	2,7
+5	3,3
+10	4,0

KSOF-150 KSOF-160	k
-10	2,0
-5	2,8
0	3,6
+5	4,4
+10	5,3
+15	6,2

KSOF-200	k
-3	1,4
0	2,1
+5	3,4
+10	4,6
+15	5,8
+20	7,1
+25	8,3



Inspection and cleaning have to be done according to national regulations or minimum twice a year.

WARNING! Please handle carefully springloaded release mechanism.

Tarkastus ja puhdistus on tehtävä kansallisten määräysten mukaisesti tai vähintään kaksi kertaa vuodessa.

VAROITUS! Käsittele varoen joukskuormitettua laukaisumekanismia.

Inspektion och rensning skall göras enligt nationella bestämmelser eller minimum två gånger per år.

WARNING! Hantera försiktigt fjäder utlösning mekanism.

1. Product: Fire Damper Valve KSOF
2. Intended use: Fire damper to be used in conjunction with fire separating elements to maintain fire compartmentation
3. Manufacturer: FläktGroup Finland Oy, Kalevantie 39, FI-20520 Turku, Finland
Tel. +358204423000, Email: info.fi@flaktgroup.com
4. System of AVCP: System 1
5. Harmonized standard: EN 15650:2010
6. Notified Body: RISE Research Institutes of Sweden AB, Nr. 0402
Performed determination the product type on the basis of type testing; initial inspection of the manufacturing plant and of factory production control; continuous surveillance, assessment and evaluation of the factory production control (FPC) under system 1 and issued: Certificate of constancy of performance - 0402-CPR-SC0768-13.
7. Declared performance:

Essential characteristics	Performance		
Nominal activation conditions/sensitivity: - sensing element load bearing capacity - sensing element response temperature	Pass		
Response delay (response time): - closure time	Pass		
Operational reliability: - cycling	Pass (50 cycles)		
Fire resistance (300 Pa):	Installation in flexible wall	Installation in rigid wall	Installation in rigid floor
- integrity	E 60	E 120	E 120
- insulation	-	-	-
- smoke leakage	E 45 S	E 120 S	E 60 S
- mechanical stability (under E)	Pass	Pass	Pass
- maintenance of the cross section (under E)	Pass	Pass	Pass
Durability of response delay: - sensing element response to temperature and load bearing capacity	Pass		
Durability of operational reliability: - open and closing cycle tests	NPD		

The performance of the product identified above is in conformity with the set of declared performance. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:

Jari Hokkanen, R&D Manager

Turku 28.10.2019